




**COMPLIANCE
ENGINEERING**

EMC Product Safety Environmental Shielding

90 Indian Drive
Keysborough VIC 3173 Australia
Telephone: + 61 3 9763 3079
Email: info@compeng.com.au
Web: www.compeng.com.au
ABN: 56 101 639 588

CEP-100DTC Tubular RF Power Filter

RF Shielded Enclosure, Faraday Cage, RF Shielded Room



Rated Voltage:	250 VAC
Rated Current:	100 A
Insulation test:	2250 VDC
Leakage Current:	≤ 200 mA

